



## Product certificate K22875/09

Issued 2023-01-01

Replaces K22875/08

Page 1 of 3

### Heat Exchangers

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### SWEP International AB

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

**BRL-K656:** "Heat exchangers intended for the indirect adjustment of the temperature of drinking water", dated: 2021-04-16.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

287180711

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

**Company**  
SWEP International AB  
Hjalmar Brantings väg 5  
261 43 LANDSKRONA  
Sweden  
Tel. +46 418400400  
[info@swep.net](mailto:info@swep.net)  
[www.swep.net](http://www.swep.net)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Heat Exchangers

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate

#### Heat exchangers, soldered:

##### Single partition type:

- E5T, IC5T
- E5AS, IC5AS
- E5P
- E6T, IC6T
- E8T, IC8T
- 10T, IC10T
- 25T, IC25T

##### Double partition type:

- 8DW-M
- 16DW
- 35TDW

#### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

#### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" 

Place of the mark: on the identification plate of the heat exchanger.

##### Compulsory specifications:

- Trade mark/type or logo;
- Construction (single-partition/double-partition) ;
- Secondary side wall material used;
- Intended purpose of use of the connection ends;
- Year of manufacture;
- Primary side working pressure;
- Secondary side working pressure;
- Designation of liquid intermediate medium;
- Maximum primary water temperature;
- Maximum secondary water temperature;
- Marking of primary and secondary connection ends.

##### Method of marking:

- Non-erasable;
- visible after assembly.

#### APPLICATION AND USE

The heat exchangers are intended to be used in hot water installations with a working pressure of maximum 1 MPa and a water temperature of maximum 90 °C.

## Heat Exchangers

---

### **RECOMMENDATIONS FOR CUSTOMERS**

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- SWEF International AB

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.